CONFLOW s.p.a.
Via Lecco 69/71
20864 AGRATE BRIANZA (MB) - ITALY

COMPANY WITH QUALITY SYSTEM CERTIFIED BY DNV GL = ISO 9001 =

UK CA

Declaration of conformity according to PRESSURE EQUIPMENT (SAFETY) REGULATIONS

A. **Description**: **Valves HP60 Series**
Serial Numbers: various
Marked on identification plate

Materials	Design Temperature °C	
ASTM A 216 WCB	**– 20**	**+ 425**
ASTM A 352 LCB	**– 46**	**+ 340**
S.S. ASTM A351 – CF8M	**– 196**	**+ 425**

B. **Table 6 - Piping reffered to in Article 4 (1) (c) (i), first indent – GROUP OF FLUID 1**

PN 63	PN 100	ANSI 300	ANSI 600
DN 25			
4/3			

C. Conformity Assessment procedures followed :

SEP

CERTIFICATE OF CONFORMITY This product has been manufactured, tested and inspected in accordance with our Quality Assurance System UNI EN ISO 9001. We certify that it contents correspond to the order placed and its performance is in conformance with our technical specifications.

CONFLOW s.p.a.
Firma del Costruttore – Manufacturer Signature
Roberto Lazzari – Technical Manager

Data di Rilascio / Date of Issue
14/03/2023

CONFLOW s.p.a.
Via Lecco 69/71
20864 AGRATE BRIANZA (MB) - ITALY

COMPANY WITH QUALITY SYSTEM CERTIFIED BY DNV GL = ISO 9001 =

UK CA

Declaration of conformity according to PRESSURE EQUIPMENT (SAFETY) REGULATIONS

A. **Description**: **Valves HP60 Series**
Serial Numbers: various
Marked on identification plate

Materials	Design Temperature °C	
ASTM A 216 WCB	**– 20**	**+ 425**
ASTM A 352 LCB	**– 46**	**+ 340**
S.S. ASTM A351 – CF8M	**– 196**	**+ 425**

B. **Table 6 - Piping reffered to in Article 4(1) (c) (i), first indent – GROUP OF FLUID 1**

PN 63 / PN 100 / ANSI 300 / ANSI 600
DN 40 – 100 CAT. II°

C. **Conformity Assessment procedures followed :**

SCHEDULE 1° - MODULE H – Certificate No. 23-UK-PER-003-H 13 January 2023 Revision No. 00

by DNV UK Limited
Approved Body n° 0097

CERTIFICATE OF CONFORMITY This product has been manufactured, tested and inspected in accordance with our Quality Assurance System UNI EN ISO 9001. We certify that it contents correspond to the order placed and its performance is in conformance with our technical specifications.

CONFLOW s.p.a.
Firma del Costruttore – Manufacturer Signature
Roberto Lazzari – Technical Manager

Date of Issue
14/03/2023